




MISSOURI
DEPARTMENT OF
NATURAL RESOURCES

Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077



Public Water System Bacteriological Report

PWS Name : COLE CAMP PWS
Mail to : CLINTON RAETZ
401 W MAIN ST
COLE CAMP, MO 65325

PWS ID : MO3010180

County : BENTON

Please notify us of any
name and address changes

Date Collected :	Collector :	Sample Type :
10/07/2026	LEIMKUEHLER,KIRK	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1485302	405 W. BUTTERFIELD	15
Lab Results :		
A		

Coliform absent. Sample considered safe.

Date Collected :	Collector :	Sample Type :
10/07/2026	LEIMKUEHLER,KIRK	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1485301	FIRE STATION	19
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.

Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Tuesday, October 13, 2026