



Public Drinking Water Branch
P.O. Box 176
Jefferson City, MO 65102
(573)751-1077

Public Water System Bacteriological Report

PWS Name : COLE CAMP PWS
Mail to : DJ HAYES
401 E MAIN ST
COLE CAMP, MO 65325

PWS ID : MO3010180

County : BENTON

Please notify us of any
name and address changes


Date Collected :	Collector :	Sample Type :
03/09/2026	HAYES,DJ	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1368666	407 NORTH PINE	02
Lab Results :		
A		

Coliform absent. Sample considered safe.

Date Collected :	Collector :	Sample Type :
03/09/2026	HAYES,DJ	Routine
Lab Sample ID :	Location Name:	Location ID:
OE1368667	120 HAZLETT	14
Lab Results :		
A		

Coliform absent. Sample considered safe.

These sample test results were analyzed by the Missouri State Public Health Laboratory.



Note to Public Water Systems:

Routine samples must be taken from the distribution system. Routine samples collected at the well will be invalidated, possibly resulting in your system receiving a monitoring violation for failure to collect enough valid routine samples. If you have any questions about these sample results, call 573-526-0135.

Thursday, March 12, 2026