

City of Cole Camp

Public Works Update

Presented by: Public Works Director

Meeting Date: September 17, 2026

Wastewater

- Basin pumps at the sewer plant have been repaired.
- The Land Use Plan is being drafted for the DNR Wastewater Treatment Facility permit.
- The lift station on B Highway has been repaired and is operating. One pump is still not priming. Public Works will troubleshoot the priming issue next week.
- Public Works is looking into the possibility of lining the sewer pipe at Pine & Eickhoff to address the leak found during the July 23 smoke test. Lining may be an alternative to excavation, which would be difficult at this intersection because of the nearby 2-inch and 4-inch gas lines.

Water Department

- Daily water tower observations continue, including monitoring water pressure and water flow.
- Fire hydrants are being flushed, with the goal of completing the work by the end of next week.
- Daily utility locate requests are being completed.
- Public Works is researching grant funding through the State Revolving Fund to help offset the cost of touchless water meter sensors.

Streets Department

- **North Maple Street:** Dirt work and debris around the drain grate have been cleaned up.

- **Double Arch:** Two replacement rail panels have been completed and are expected to be delivered with the east-side railing in approximately 3–4 weeks.
- Double Arch has confirmed that it will address the remaining items on the City's punch list, including concrete patching, saw-cut repairs, cleaning building faces, and other touch-up work. The Aldermen and Public Works are aware of the remaining items.
- The culvert replacement at B Highway & Deer Run Lane has been completed.
- **Cole Camp Fair:** Preparations and cleanup are complete. Barricades and trash cans were placed, with trash pickup scheduled every morning during the fair and Saturday afternoon.

Parks & Library

- Mowing continues on all City properties, including both parks and the Library grounds.